

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHEISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1090520

Product: Fuses for photovoltaic systems

Type: PF10gR

Rating: 900 V DC; 4, 6, 8, 10, 12, 16, 20 A

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 902127-01/01 of: 03.06.2009

A sample of the product was found to be in conformity with:
ČSN EN 60269-4:08 ed.2, ČSN EN 60269-1:08 ed.3

The validity of the certificate is limited to: 30.6.2012

18.6.2009

Prague

Miroslav Sedláček
Certification and Inspection Manager



Stamp



* C E R / 1 0 9 0 5 2 0 *

902127-01