



CB TEST CERTIFICATE

Ref. Certificate No.

NL-20648

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.
Product:	Rotary switch disconnecter
Applicant:	Santon International B.V. Hekendorpstraat 69 3079 DX ROTTERDAM The Netherlands
Manufacturer:	Santon International B.V. Hekendorpstraat 69 3079 DX ROTTERDAM The Netherlands
Factory:	Santon Holland B.V. Berkenwoudestraat 4-6 3079 JA ROTTERDAM The Netherlands
Rating and principal characteristics:	Rotary switch disconnecter with 4 positions 90°, both directions, DC-21B, Ui 1000 V, Uimp 8 kV, Icw 500 A – 1 s, Icm 500 A, maximum 9 layers. For further information see annex
Trade mark (if any):	SANTON
Model/Type reference:	XA80.25..., XA75.25..., XA75.16..., XA75.10..., XA60.25..., XA60.16..., XA60.10...
Additional information:	
Sample of product tested to be in conformity with IEC:	60947-3(ed.3)
Test Report Ref. No:	2143635.50

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2011-05-23



DEKRA Certification is
former KEMA Quality

Ratings and principal characteristics:

Rotary switch disconnecter with 4 positions 90°, both directions, maximum 9 layers, contact composition during the tests 1 contacts in series in the '+' pole and 1 contact in the '-' pole.

IP20 or IP65 when build-in an enclosure with gland of the shaft for panel mounting.

Method of mounting: Front: single hole mounting; bottom: screw mounting and/or top-hat rail mounting.

General:

Ratings: DC-21B Ui 1000 V, Uimp 8 kV

Icw 500 A - 1 s, Icm 500 A

For ambient temperature: -5 °C to 70 °C.

Type	Ue (Vdc)	Ie (A)
XA80.25...	800	25
XA75.25...	750	25
XA75.16...	750	16
XA75.10...	750	10
XA60.25...	600	25
XA60.16...	600	16
XA60.10...	600	10