



CB TEST CERTIFICATE

Ref. Certificate No.

NL-20649

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

| | | | |
|--|---|--|-----------------|
| Issued by: | DEKRA Certification B.V. | | |
| Product: | Rotary switch disconnecter | | |
| Applicant: | Santon International B.V. | Hekendorpstraat 69 3079 DX ROTTERDAM | The Netherlands |
| Manufacturer: | Santon International B.V. | Hekendorpstraat 69 3079 DX ROTTERDAM | The Netherlands |
| Factory: | Santon Holland B.V. | Berkenwoudestraat 4-6 3079 JA ROTTERDAM | The Netherlands |
| Rating and principal characteristics: | Rotary switch disconnecter with 4 positions 90°, both directions, DC-21B, Ue: 850 V, Ui 1000 V, Uimp 8 kV, Icw 500 A – 1 s, Icm 500 A, maximum 9 layers. For further information see annex | | |
| Trade mark (if any): | SANTON | | |
| Model/Type reference: | XA85.20..., XA85.10... | | |
| Additional information: | | | |
| Sample of product tested to be in conformity with IEC: | 60947-3(ed.3) | | |
| Test Report Ref. No: | 2143635.51 | | |

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: F.S. Strikwerda

Date of issue: 2011-05-23



DEKRA Certification is
former KEMA Quality

Ratings and principal characteristics:

Rotary switch disconnecter with 4 positions 90°, both directions, maximum 9 layers, contact composition during the tests 1 contacts in series in the '+' pole and 1 contact in the '-' pole.

IP20 or IP65 when build-in an enclosure with gland of the shaft for panel mounting.

Method of mounting: Front: single hole mounting; bottom: screw mounting and/or top-hat rail mounting.

General:

Ratings: DC-21B, Ue 850 V

Ie 20 A for XA85.20..., 10 A for XA85.10...

Ui 1000 V, Uimp 8 kV

Icw 500 A - 1 s, Icm 500 A

For ambient temperature: -5 °C to 70 °C.

A handwritten signature in blue ink, located in the bottom right corner of the page.