



CB TEST CERTIFICATE

Ref. Certificate No.

NL-20650

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Rotary switch disconnecter		
Applicant:	Santon International B.V.	Hekendorpstraat 69 3079 DX ROTTERDAM	The Netherlands
Manufacturer:	Santon International B.V.	Hekendorpstraat 69 3079 DX ROTTERDAM	The Netherlands
Factory:	Santon Holland B.V.	Berkenwoudestraat 4-6 3079 JA ROTTERDAM	The Netherlands
Rating and principal characteristics:	Rotary switch disconnecter with 4 positions 90°, both directions, DC-21B, Ue: 1000 V, Ui 1000 V, Uimp 8 kV, Icw 500 A – 1 s, Icm 500 A, maximum 9 layers. For further information see annex		
Trade mark (if any):	SANTON		
Model/Type reference:	XA100.16..., XA100.10...		
Additional information:			
Sample of product tested to be in conformity with IEC:	60947-3(ed.3)		
Test Report Ref. No:	2143635.52		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2011-05-23



DEKRA Certification is
former KEMA Quality

Ratings and principal characteristics:

Rotary switch disconnecter with 4 positions 90°, both directions, maximum 9 layers, contact composition during the tests 1 contacts in series in the '+' pole and 1 contact in the '-' pole.

IP20 or IP65 when build-in an enclosure with gland of the shaft for panel mounting.

Method of mounting: Front: single hole mounting; bottom: screw mounting and/or top-hat rail mounting.

General:

Ratings: DC-21B, Ue 1000 V

Ie 16 A for XA100.16..., 10 A for XA100.10...

Ui 1000 V, Uimp 8 kV

Icw 500 A - 1 s, Icm 500 A

For ambient temperature: -5 °C to 70 °C.