

ATTESTATION OF CONFORMITY

Issued to: Santon International B.V.
Hekendorpstraat 69
3079 DX Rotterdam

For the product: Switch-disconnectors with 2 positions 90°, both directions

Trade name: SANTON

Type/Model: XBHP....

Ratings: Ue 1100 V, Ie 10 A, DC21-B, Ui 1100 V, Uimp 8 kV, ambient -40 °C -75 °C,
maximum 6 poles (one pole one contact, 2 poles switching per circuit).

Manufactured by: Santon International B.V.
Hekendorpstraat 69
3079 DX Rotterdam

Subject: Sequences I and II of IEC 60947-3

Requirements: IEC 60947-3:2008 + C1:2013 + A1:2012

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential test report No. 2184962.50.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 9 September 2015

Number: 2184962.01A

DEKRA Certification B.V.

H.L. Schendstok
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed