



Product Service

CERTIFICATE

No. B 104315 0002 Rev. 00

Holder of Certificate: **JD Auspice Co., Ltd.**
2F-5, No. 7, Lane 43, Shuangcheng St.
Zhongshan District
10461 Taipei City
TAIWAN

Production Facility(ies): 078767

Certification Mark:



Product: **Electric Cables**
Electric cables for photovoltaic systems with a voltage rating of 1,5kV DC

Model(s): **62930 IEC 131 1×2,5...16mm²**

Parameters:

Rated Voltage:	DC 1500V (between conductors and between conductor and earth) AC U ₀ /U: 1,0/1,0 kV
Application Class:	A
Protection Class:	II
Ambient Temperature:	-40°C ~ +90°C
Max. Temperature at conductor:	120°C

Tested according to: IEC 62930(ed.1.0)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262010101-00
Valid until: 2024-03-31
Date, 2020-08-17

(Yaqu Alex Liu)