

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50471265

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
X.Y.J.

Unser Zeichen *Our Reference*
01-SSC-50079839 002

Ausstellungsdatum *Date of Issue*
07.08.2020 (day/mo/yr)

Genehmigungsinhaber *License Holder*

JD Auspice Co., Ltd.
3F., No. 288, Sec. 2 Zhonghua Rd.,
Xinzhuang Dist., New Taipei City
242
Taiwan

Fertigungsstätte *Manufacturing Plant*

040-0002083015

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111225255

Geprüft nach *Tested acc. to*

EN 60947-3:2009+A1+A2

EN 60947-1:2007+A1+A2

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product (Product Identification)

Lizenzentgelte - Einheit

License Fee - Unit

Fuse Holder (Fuse-disconnector)

Type Designation	: FH-01LS	5
Utilization Category	: DC-PV0	
Number of Pole	: 1-pole	
Rated Operational Voltage Ue	: 1000V	
Rated Operational Current Ie	: 30A	
Rated Insulation Voltage Ui	: 1000V	
Rated Impulse Withstand Voltage Uimp	: 8kV	
Conventional Free Air Thermal Current Ith	: same as Ie	
Conditional Short-circuit Current	: 33kA	
Pollution Degree	: 3	
Degree of Protection	: IP20, after installation	

5

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle

Kenny Shi