

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50526328

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
Z.D.Y

Unser Zeichen *Our Reference*
01-SDW-CN2107YT 002

Ausstellungsdatum *Date of Issue*
02.12.2021 (day/mo/yr)

Genehmigungsinhaber *License Holder*
JD Auspice Co., Ltd.
3F., No. 288, Sec. 2
Zhonghua Rd., Xinzhuang Dist.,
New Taipei City 242
Taiwan

Fertigungsstätte *Manufacturing Plant*
040-0002313994

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111247785

Geprüft nach *Tested acc. to*
EN 60269-6:2011
EN 60269-1:2007+A1+A2

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Fuse Link (Low-voltage Fuse for PV System)

Type Designation : gPV-85 xA
x=8;10;12;15;16;20;25;30;32;35

Rated Voltage : DC 1500V

Rated Current : 8A;10A;12A;15A;16A;20A;25A;30A;
32A;35A

Rated Breaking Capacity: 50kA

Breaking Range : gPV

Rated Power Dissipation: no more than 4W at 0,7In
no more than 7W at In

Size : 10*85

Arc Voltage Limits : 5000V (peak value)

6

6

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Zertifizierungsstelle



Kenny Shi