

測試報告

報告日期:2022-02-11

報告編號:11055C00584-1-5-01

版次:A

1	1	TI	13
1	計	項	\boldsymbol{B}
_	- 0	/	

名稱: 日照計累積照度比對測試

廠牌: -----

型號: -----

序號: -----

委託顧客

名稱: 日煬科技有限公司

地址: 新北市新莊區中華路2段288號3樓

上述委託項目經本實驗室 測試,結果如內文。

本報告含簽署頁及內文共 10 頁,分離使用無效。



王人選

黄朝楼

綠能與環境研究所 所長 部門主管

2022/02/14 08:26:39 637804239991272350

委託資訊:

樣品名稱:日照計

廠牌、型號、序號:參考表格一

測試期間: 2021年08月10日至2021年12月31日

測試實驗室資訊:

名稱: 太陽光電系統測試實驗室

地址: 台南市歸仁區高發二路 360 號 B 棟 2 樓 220 室

電話: +886-6-3636861 傳真: +886-6-3032029

杂洪義

報告簽署人

杂洪義

實驗室主管

測試結果與說明

I. 測試結果:

日照計資訊

表格一				
項目	廠牌	型號	序號	提供日照計者
表格A	Hukseflux	SR30-D1	6586	工研院-綠能所-太陽光電技術組 -R300-太陽光電系統測試實驗室
表格B	Deltaohm	PYRA03AC	21013200	日煬科技
表格C	Hukseflux	SR05-D2A2	9379	日煬科技

2. 測試地點資訊:

2. 测试地制具机.					
表格二人					
委託客戶名稱	日煬科技有限公司				
案場地址	台南市歸仁區高發二路 360 號 C 棟屋頂				
案場資訊 B					
	A(22°55'15.4"N 120°17				
經緯度	B(22°55'13.0"N 120°17'30.6"E) C(22°55'13.8"N 120°17'32.8"E)				
	D(22°55'16.1"N 120°17'31.8"E)				
	請取頻率	三秒鐘			
次则连四一一一种,却从时和	紀錄頻率	一分鐘			
資料讀取、紀錄、報告時程	報告期間	2021/08/10~2021/12/31			
日照計測試角度	量測水平日照量				

3. 監測元件資訊:				
表格A				
量測元件	日照計			
元件數量	1 件			
廠牌	Hukseflux	A.		
型號/序號	SR30-D1/6586	. (
元件位置説明				
	日照計安裝於上圖			
維護資訊	校正 (2) 校正報告編號: 無校正資訊			
元件技術類型		等級		

3/10

11055C00584-1-5-01

	Class A	 Secondary standard per ISO 9060 ☐ High quality per WMO Guide No. 8 (Uncertainty ≤ 3 % for hourly totals)
Thermopile pyranometers	☐ Class B	 ☐ First class per ISO 9060 ☐ Good quality per WMO Guide No. 8 (Uncertainty ≤ 8 % for hourly totals)
	☐ Class C	Any:
	☐ Class A	Uncertainty ≤ 3 % from (100 ~1500) W·m ²
□ PV reference cell□ PV reference module	☐ Class B	Uncertainty ≤ 8 % from (100 ~1500) W·m²
	☐ Class C	Any:
	Class A	Not applicable:
☐ Photodiode sensors	☐ Class B	Not applicable:
4EX	☐ Class C	Any:

	表格B
量測元件	日照計
元件數量	1 pcs
廠牌	Deltaohm
型號/序號	PYRA03AC/21013200
元件位置説明	LP PYRA 03 AC \$\frac{\frac{1}{2}}{2\triangle \text{N}} \tag{2101320}{\frac{1}{2}}{\tag{2}}{\

11055C00584-1-5-01

維護資訊	日照計安裝於上圖紅色圓圖處 校正 無校正資訊		
		Classified	
Sensor type	☐ Class A	 ☐ Secondary standard per ISO 9060 ☐ High quality per WMO Guide No. 8 (Uncertainty ≤ 3 % for hourly totals) 	
Thermopile pyranometers	☐ Class B	☐ First class per ISO 9060 ☐ Good quality per WMO Guide No. 8 (Uncertainty ≤ 8 % for hourly totals)	
><	Class C	Any: Second class pyranometer according to ISO 9060.	
	☐ Class A	Uncertainty ≤ 3 % from (100 ~1500) W·m ²	
□ PV reference cell□ PV reference module	☐ Class B	Uncertainty $\leq 8 \%$ from (100 ~1500) W·m ²	
NO CO	Class C	Any:	
	☐ Class A	Not applicable:	
☐ Photodiode sensors	☐ Class B	Not applicable:	
	☐ Class C	Any:	

11055C00584-1-5-01

	表格C
量測元件	日照計
元件數量	1 pcs
廠牌	Hukseflux
型號/序號	SR05-D2A2/9379
元件位置説明	Roder SISCULATION PROPERTY OF THE PROPERTY OF



Industrial Technology Research Institute 報告編號:

11055C00584-1-5-01

	日照計安裝於上圖紅色圓圈處		
維護資訊	校正	無校正資訊	
Sensor type		Classified	
	☐ Class A	☐ Secondary standard per ISO 9060 ☐ High quality per WMO Guide No. 8 (Uncertainty ≤ 3 % for hourly totals)	
Thermopile pyranometers	☐ Class B	 ☐ First class per ISO 9060 ☐ Good quality per WMO Guide No. 8 (Uncertainty ≤ 8 % for hourly totals) 	
	Class C	Any: Second class pyranometer according to ISO 9060.	
	☐ Class A	Uncertainty ≤ 3 % from (100 ~1500) W·m ²	
□ PV reference cell□ PV reference module	☐ Class B	Uncertainty $\leq 8 \%$ from (100 ~1500) W·m ²	
NO ST	☐ Class C	Any:	
	☐ Class A	Not applicable:	
☐ Photodiode sensors	☐ Class B	Not applicable:	
	☐ Class C	Any:	

1. 測試結果:

	日照累積(kWh/m²)			
日期(日照累積期間)	型號:SR30-D1	型號:LPPYRA03AC	型號:SR05-D2A2	
	序號:6586	序號:21013200	序號:9379	
2021/08/10~2021/08/28	70.19	66.85	70.13	
2021/09/03~2021/09/30	145.22	138.58	145.12	
2021/11/04~2021/11/30	103.73	100.46	103.68	
2021/12/01~2021/12/31	113.36	108.57	111.10	
2021/08/10~2021/12/31	432.50	414.46	430.03	
误差值比較 以 SR30-D1 為基準)	N/A	3.1%	1.6%	

備註:

- (1) 2021 年 10 月監測系統電力異常,故無日照量數據。
- (2) 2021/08/10~2021/08/28 測試報告編號: 11055C00584-1-1-01-RPT-3
- (3) 2021/09/03~2021/09/30 測試報告編號: 11055C00584-1-2-01-RPT-2
- (4) 2021/11/04~2021/11/30 測試報告編號: 11055C00584-1-3-01-RPT-1
- (5) 2021/12/01~2021/12/31 測試報告編號: 11055C00584-1-4-01-RPT-1

Ⅱ. 說明:

1. 測試日期與案場位置:

測試時間為 2021 年 08 月 10 日至 2021 年 12 月 31 日,在工研院表 2 案場地址進行。

依據 IEC 61724-1:2017 進行元件規格說明、執行監測數據以及日照量累積計算。

III. 參考資料

1. IEC 61724-1: 2017, first edition, Photovoltaic system performance –Part 1: Monitoring.





測試報告

報告日期:2022-02-11

報告編號:11055C00584-1-6-01

版次:A

委託項目

名稱: 日照計累積照度比對測試

廠牌: -----

型號: -----

序號: -----

委託顧客

名稱: 日煬科技有限公司

地址: 新北市新莊區中華路2段288號3樓

上述委託項目經本實驗室 測試,結果如內文。

本報告含簽署頁及內文共_11_頁,分離使用無效。



王人議

黄朝楼

綠能與環境研究所 所長 部門主管

2022/02/14 08:26:58 637804240189200168

報告編號: 11055C00584-1-6-01

本報告屬日煬科技所有,請勿複製

委託資訊:

樣品名稱: 日照計

麻牌、型號、序號:參考表格一

測試期間: 2022年01月01日至2022年01月31日

測試實驗室資訊:

名稱: 太陽光電系統測試實驗室

地址: 台南市歸仁區高發二路 360 號 B 棟 2 樓 220 室

電話: +886-6-3636861 傳真: +886-6-3032029

報告簽署人

實驗室主管

1/10

本報告屬日煬科技所有,請勿複製

測試結果與說明

I. 測試結果:

1. 日照計資訊

		AT POST OF	表格一	HEREXA THE EATHER
項目	廠牌	型號	序號	提供日照計者
表格 A	Hukseflux	SR30-D1	6586	工研院-綠能所-太陽光電技術組 -R300-太陽光電系統測試實驗室
表格 B	Deltaohm	PYRA03AC	21013200	日煬科技
表格C	Hukseflux	SR05-D2A2	9379	日煬科技

2. 測試地點資訊:

2. 外码地面负配。			
	表格二		
委託客戶名稱	日煬科技有限公司		
案場地址	台南市歸仁區高發二	路 360 號 C 棟屋頂	
案場資訊 B			
A(22°55'15.4"N 120°17'29.6"E) B(22°55'13.0"N 120°17'30.6"E) C(22°55'13.8"N 120°17'32.8"E) D(22°55'16.1"N 120°17'31.8"E)		7'30.6"E) 7'32.8"E)	
	讀取頻率	三秒鐘	
資料讀取、紀錄、報告時程	紀錄頻率	一分鐘	
	報告期間	31 天 (2022/01/01~2022/01/31)	
日照計測試角度	量測水平日照量		

監測元件資訊:

3. 監測元件資訊:	
	表格A
量測元件	日照計
元件數量	1 件
廠牌	Hukseflux
型號/序號	SR30-D1/6586
元件位置説明	D C C C C C C C C C C C C C C C C C C C
維護資訊	校正 (1) 每年校正 (2) 校正報告編號: 無校正資訊
元件技術類型	等級

	Class A	Secondary standard per ISO 9060☐ High quality per WMO Guide No. 8(Uncertainty ≤ 3 % for hourly totals)	
Thermopile pyranometers	☐ Class B	 ☐ First class per ISO 9060 ☐ Good quality per WMO Guide No. 8 (Uncertainty ≤ 8 % for hourly totals) 	
	☐ Class C	Any:	
	☐ Class A	Uncertainty ≤ 3 % from (100 ~1500) W·m²	
□ PV reference cell□ PV reference module	☐ Class B	Uncertainty ≤ 8 % from (100 ~1500) W·m ²	
	☐ Class C	Any:	
¥	☐ Class A	Not applicable:	
☐ Photodiode sensors	☐ Class B	Not applicable:	
	☐ Class C	Any:	



ALTERNATION OF	表格 B
量測元件	日照計
元件數量	1 pcs
廠牌	Deltaohm
型號/序號	PYRA03AC/21013200
元件位置説明	LP PYRA 03 AC S/N 2101320 4mA — OWINI 20mA — ZOOOWIS



	日照計安裝於上圖紅色圓圖處		
維護資訊	校正	無校正資訊	
Sensor type		Classified	
	☐ Class A	 ☐ Secondary standard per ISO 9060 ☐ High quality per WMO Guide No. 8 (Uncertainty ≤ 3 % for hourly totals) 	
Thermopile pyranometers	☐ Class B	☐ First class per ISO 9060 ☐ Good quality per WMO Guide No. 8 (Uncertainty ≤ 8 % for hourly totals)	
	Class C	Any: Second class pyranometer according to ISO 9060.	
	Class A	Uncertainty $\leq 3 \%$ from $(100 \sim 1500) \text{ W} \cdot \text{m}^2$	
☐ PV reference cell ☐ PV reference module	☐ Class B	Uncertainty $\leq 8 \%$ from (100 ~1500) W·m ²	
	Class C	Any:	
	☐ Class A	Not applicable:	
☐ Photodiode sensors	☐ Class B	Not applicable:	
3	☐ Class C	Any:	



Elegistra e	表格C
量測元件	日照計
元件數量	1 pcs
廠牌	Hukseflux
型號/序號	SR05-D2A2/9379
元件位置説明	
	model: SROS-02A3 sental to 3.979 output: digital and 4.35m



	日照計安裝於上圖紅色圓圈處		
維護資訊	校正	無校正資訊	
Sensor type	F.	Classified	
	☐ Class A	☐ Secondary standard per ISO 9060 ☐ High quality per WMO Guide No. 8 (Uncertainty ≤ 3 % for hourly totals)	
Thermopile pyranometers	☐ Class B	☐ First class per ISO 9060 ☐ Good quality per WMO Guide No. 8 (Uncertainty ≤ 8 % for hourly totals)	
	Class C	Any: Second class pyranometer according to ISO 9060.	
	Class A	Uncertainty ≤ 3 % from (100 ~1500) W·m ²	
□ PV reference cell□ PV reference module	☐ Class B	Uncertainty $\leq 8 \%$ from (100 ~1500) W·m ²	
	☐ Class C	Any:	
	☐ Class A	Not applicable:	
☐ Photodiode sensors	☐ Class B	Not applicable:	
2	☐ Class C	Any:	



1. 測試結果:

		日照計型號/序號			
日期	日照統計時間(#註1	SR30-D1	LPPYRA03AC	SR05-D2A	
		6586	21013200	9379	
2022/01/01 衛柱 2	06:59:21~17:08:12	4.83	4.68	4.76	
2022/01/02	06:57:00~17:08:00	4.69	4.56	4.64	
2022/01/03	06:56:15~17:09:06	4.66	4.49	4.58	
2022/01/04	07:04:06~17:01:00	3.77	3.65	3.71	
2022/01/05	07:18:30~16:51:45	2.86	2.76	2.81	
2022/01/06	07:21:27~16:49:36	3.06	2.95	2.99	
2022/01/07	07:08:12~17:02:45	4.29	4.18	4.23	
20220/1/08	07:04:21~17:17:48	4.40	4.26	4.35	
2022/01/09	07:00:48~17:19:12	4.59	4.42	4.53	
2022/01/10	06:56:33~17:21:15	4.50	4.35	4.45	
2022/01/11	07:16:12~18:06:27	3.11	3.21	3.06	
2022/01/12	07:09:21~17:23:15	1.98	1.92	1.96	
2022/01/13	06:53:09~17:11:48	4.52	4.39	4.48	
2022/01/14	06:54:27~17:16:03	4.50	4.33	4.43	
2022/01/15	06:57:06~17:21:00	4.61	4.44	4.58	
2022/01/16	06:56:57~17:09:51	4.51	4.37	4.47	
2022/01/17	06:54:51~16:50:06	3.92	3.79	3.86	
2022/01/18	07:15:06~17:20:51	1.79	1.72	1.74	
2022/01/19	07:07:42~17:23:24	3.82	3.73	3.81	
2022/01/20	07:01:33~17:18:03	3.97	3.81	3.89	
2022/01/21	06:56:57~17:20:03	3.45	3.32	3.40	
2022/01/22	07:55:39~16:36:15	1.71	1.65	1.68	
2022/01/23	07:00:42~16:57:15	3.23	3.11	3.21	
2022/01/24	07:32:54~17:17:45	2.56	2.50	2.55	
2022/01/25	06:58:39~17:27:27	4.33	4.20	4.33	
2022/01/26	06:56:24~17:27:27	4.62	4.45	4.61	
2022/01/27	07:25:12~17:24:33	4.35	4.22	4.35	
2022/01/28	07:00:24~16:13:51	1.87	1.79	1.81	
2022/01/29	07:48:36~17:24:03	1.26	1.22	1.22	
2022/01/30	07:06:03~17:03:15	1.88	1.78	1.83	
2022/01/31	07:06:27~17:08:39	4.28	4.20	4.25	
2022/01/01~20	22/01/31 日照累積量	111.93	108.42	110.59	
誤差值比較(以 SR30-D1 為基準)	N/A	3.14%	1.20%	

備註 1:依據 IEC 61724-1 要求當日照亮大於等於 20 W/m²時,視為有效日照用於排除夜晚監 測數據,以有效正日照計型號為 SR30-D1 判斷有效日照。

備註 2:開始進行測試

11055C00584-1-6-01

本報告屬日煬科技所有,請勿複製

II. <u>說明</u>:

- 測試日期與案場位置
 測試時間為2022年01月01日至2022年01月31日,在工研院表2案場地址進行。
- 2. 依據 IEC 61724-1:2017 進行元件規格說明、執行監測數據以及日照量累積計算。

III. 參考資料

1. IEC 61724-1: 2017, first edition, Photovoltaic system performance -Part 1: Monitoring.





測試報告

報告日期: 2022-03-14

報告編號:11055C00584-1-7-01

版次:A

委託項目

名稱: 日照計累積照度比對測試

廠牌: -----

型號: -----

委託顧客

名稱: 日煬科技有限公司

地址:新北市新莊區中華路2段288號3樓

上述委託項目經本實驗室 測試,結果如內文。

本報告含簽署頁及內文共 11 頁,分離使用無效。



王人議

黄朝楼

綠能與環境研究所 所長 部門主管

2022/03/14 08:57:15 637828450356116594

11055C00584-1-7-01

本報告屬日煬科技所有,請勿複製

委託資訊:

樣品名稱: 日照計

廠牌、型號、序號:參考表格一

測試期間: 2022 年 02 月 01 日至 2022 年 02 月 28 日

測試實驗室資訊:

名稱: 太陽光電系統測試實驗室

地址: 台南市歸仁區高發二路 360 號 B 棟 2 樓 220 室

電話: +886-6-3636861 傳真: +886-6-3032029

杂洪義

報告簽署人

亲洪義

實驗室主管

測試結果與說明

I. 測試結果:

1. 日照計資訊

表格一				
項目	廠牌	型號	序號	提供日照計者
表格A	Hukseflux	SR30-D1	6586	工研院-綠能所-太陽光電技術組 -R300-太陽光電系統測試實驗室
表格B	Deltaohm	PYRA03AC	21013200	日煬科技
表格C	Hukseflux	SR05-D2A2	9379	日煬科技

2. 測試地點資訊:

2. 测試地點頁訊:		
	表格二	
委託客戶名稱	日煬科技有限公司	
案場地址	台南市歸仁區高發二路	各 360 號 C 棟屋頂
案場資訊	A	D
經緯度	A(22°55'15.4"N 120°1' B(22°55'13.0"N 120°1' C(22°55'13.8"N 120°1' D(22°55'16.1"N 120°1	7'30.6"E) 7'32.8"E)
資料讀取、紀錄、報告時程	讀取頻率	三秒鐘
	紀錄頻率	一分鐘
	報告期間	28 天 (2022/02/01~2022/02/28)
日照計測試角度	量測水平日照量	

3. 監測元件資訊:		
	表格A	
量測元件	日照計	
元件數量	1 件	
廠牌	Hukseflux	- A
型號/序號	SR30-D1/6586	
元件位置説明	SKSU DIVISION IN THE PROPERTY OF THE PROPERTY	
	日照計安裝於上圖	(1) 每年校正
維護資訊	校正	(2) 校正報告編號: <u>11107C00444-1-1-03</u>
元件技術類型		等級



11055C00584-1-7-01

	Class A	Secondary standard per ISO 9060☐ High quality per WMO Guide No. 8(Uncertainty ≤ 3 % for hourly totals)	
Thermopile pyranometers	☐ Class B	 ☐ First class per ISO 9060 ☐ Good quality per WMO Guide No. 8 (Uncertainty ≤ 8 % for hourly totals) 	
	☐ Class C	Any:	
	☐ Class A	Uncertainty ≤ 3 % from (100 ~1500) W·m ²	
□ PV reference cell□ PV reference module	☐ Class B	Uncertainty ≤ 8 % from (100 ~1500) W·m²	
	☐ Class C	Any:	
	☐ Class A	Not applicable:	
☐ Photodiode sensors	Class B	Not applicable:	
4EX	☐ Class C	Any:	



Best Della Res	表格B
量測元件	日照計
元件數量	1 pcs
廠牌	Deltaohm
型號/序號	PYRA03AC/21013200
元件位置説明	LP PYRA 03 AC 5/N 21013200 4mA



	日照計安裝於上圖紅色圓圈處				
維護資訊	校正	無校正資訊			
Sensor type Thermopile pyranometers	☐ Class A	Classified ☐ Secondary standard per ISO 9060 ☐ High quality per WMO Guide No. 8 (Uncertainty ≤ 3 % for hourly totals)			
	☐ Class B	☐ First class per ISO 9060 ☐ Good quality per WMO Guide No. 8 (Uncertainty ≤ 8 % for hourly totals)			
	Class C	Any: Second class pyranometer according to ISO 9060.			
☐ PV reference cell☐ PV reference module	☐ Class A	Uncertainty $\leq 3 \%$ from (100 ~1500) W·m ²			
	☐ Class B	Uncertainty $\leq 8 \%$ from (100 ~1500) W·m ²			
	☐ Class C	Any:			
☐ Photodiode sensors	☐ Class A	Not applicable:			
	☐ Class B	Not applicable:			
	☐ Class C	Any:			

量測元件 日照計 元件數量 1 pcs 廠牌 Hukseflux 型號/序號 SR05-D2A2/9379
廠牌 Hukseflux
型號/序號 SR05-D2A2/9379
元件位置説明

報告編號: 11055C00584-1-7-01

	日照計安裝於上圖紅色圓圈處					
維護資訊	校正	無校正資訊				
Sensor type Thermopile pyranometers	☐ Class A	Classified ☐ Secondary standard per ISO 9060 ☐ High quality per WMO Guide No. 8 (Uncertainty ≤ 3 % for hourly totals)				
	☐ Class B	☐ First class per ISO 9060 ☐ Good quality per WMO Guide No. 8 (Uncertainty ≤ 8 % for hourly totals)				
	Class C	Any: Second class pyranometer according to ISO 9060.				
□ PV reference cell□ PV reference module	☐ Class A	Uncertainty $\leq 3 \%$ from (100 ~1500) W·m ²				
	☐ Class B	Uncertainty $\leq 8 \%$ from (100 ~1500) W·m ²				
	☐ Class C	Any:				
☐ Photodiode sensors	☐ Class A	Not applicable:				
	☐ Class B	Not applicable:				
	☐ Class C	Any:				

1. 測試結果:

1. 测訊結本.		日照計型號/序號			
日期	日照統計時間#註1	SR30-D1	LPPYRA03AC	SR05-D2A2	
	30 30 30 40 50 50 50 50 50 50 50 50 50 50 50 50 50	6586	21013200	9379	
2022/02/01 備註 2	07:00:48~17:30:03	3.94	3.83	3.92	
2022/02/02	07:00:15~17:30:06	4.92	4.78	4.90	
2022/02/03	07:03:21~17:25:42	3.28	3.19	3.25	
2022/02/04	07:04:12~17:36:45	4.90	4.80	4.92	
2022/02/05	06:57:24~17:30:21	4.71	4.60	4.67	
2022/02/06	06:47:33~17:37:00	4.68	5.14	5.30	
2022/02/07	07:13:24~17:26:27	3.20	3.10	3.17	
2022/02/08	06:59:24~17:33:37	4.70	4.57	4.69	
2022/02/09	07:20:00~17:37:42	5.10	4.97	5.13	
2022/02/10	06:58:51~17:31:03	4.92	4.81	4.89	
2022/02/11	07:24:36~17:45:15	4.42	4.31	4.32	
2022/02/12	07:00:21~17:39:54	5.11	5.03	5.12	
2022/02/13	07:19:36~17:28:48	3.98	3.80	3.70	
2022/02/14	07:18:42~17:23:03	2.59	2.50	2.56	
2022/02/15	07:13:18~17:26:33	2.69	2.60	2.66	
2022/02/16	06:49:39~17:38:12	5.18	5.55	5.21	
2022/02/17	07:32:33~17:28:51	1.93	1.86	1.86	
2022/02/18	07:35:18~17:42:57	4.30	4.16	4.28	
2022/02/19	06:58:45~16:52:03	3.46	3.37	3.39	
2022/02/20	07:56:09~16:02:00	0.55	0.54	0.52	
2022/02/21	07:41:00~17:19:51	0.81	0.77	0.75	
2022/02/22	07:02:03~16:52:00	2.13	2.06	2.04	
2022/02/23	07:40:42~17:09:57	0.98	0.95	0.93	
2022/02/24	07:11:12~17:23:48	3.22	3.13	3.14	
2022/02/25	06:39:39~17:45:48	5.87	5.69	5.59	
2022/02/26	06:48:36~17:42:18	6.01	5.85	5.85	
2022/02/27	06:47:18~17:48:48	5.73	5.58	5.61	
2022/02/28	06:35:51~17:49:21	6.26	6.02	6.15	
2022/02/01~2022/02/28 日照累積量		109.57	107.57	108.51	
誤差值比較(以 SR30-D1 為基準)		N/A	1.83%	四田払払公方曜	

備註 1:依據 IEC 61724-1 要求當日照亮大於等於 20 W/m² 時,視為有效日照用於排除夜晚監 測數據,以有效正日照計型號為 SR30-D1 判斷有效日照。 備註 2:開始進行測試

11055C00584-1-7-01

本報告屬日煬科技所有,請勿複製

II. <u>說明</u>:

- 測試日期與案場位置
 測試時間為2022年02月01日至2022年02月28日,在工研院表2案場地址進行。
- 2. 依據 IEC 61724-1:2017 進行元件規格說明、執行監測數據以及日照量累積計算。

III. 參考資料

1. IEC 61724-1: 2017, first edition, Photovoltaic system performance –Part 1: Monitoring.

